



PAT Testing Report For:

Sample - OD12345



February 2020

Summary of Results

Total Tested	Passed Items	Failed Items
68	67	1



Poundbury House, Poundbury West Industrial Estate,
Dorchester, Dorset, DT1 2PG

T. 0203 011 0582 E. reception@reaction-grp.com

Registered Office: Lupins Business Centre, 1-3 Greenhill, Weymouth, Dorset, DT4 7SP Reg. No. 5943409





NICEIC
Approved
PAT Report

Sample - OD12345

February 2020

Asset ID	Description of Item	Visual Only	Class	Supply Test	Connector / Plug Check	Case / Housing Check	Fuse Check	Visual Result	Insulation Result MΩ	Earth Bond Ω	Polarity	Voltage	Test Engineer	Location	Retest Due (Months)	Overall Pass / Fail
1627695	Broville Kettle Base	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.08	OK	230	RG	Reception Kitchen	12	PASSED
1627696	Boville Kettle	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.1	OK	230	RG	Reception Kitchen	12	PASSED
1627697	Micromark Toaster	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.03	OK	230	RG	Reception Kitchen	12	PASSED
1627698	Russel Hobbs Microwave	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.04	OK	230	RG	Reception Kitchen	12	PASSED
1627699	Masterplug 8 Gang Extension Lead	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.03	OK	230	RG	Reception Kitchen	12	PASSED
1627700	Cannon Battery Charger	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Kitchen	12	PASSED
1627701	2 Pin Lead	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Kitchen	12	PASSED
1627702	Hytera PSU/Charger	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Kitchen	12	PASSED
1627703	Hytera PSU/Charger	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Kitchen	12	PASSED
1627704	Hytera PSU/Charger	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Kitchen	12	PASSED
1627705	Hytera PSU/Charger	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Kitchen	12	PASSED
1627706	Beko Fridge	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.04	OK	230	RG	Reception Kitchen	12	PASSED
1627707	Proline Fridge	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.05	OK	230	RG	Nickys Office	12	PASSED
1627708	Fellowes Laminator	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Nickys Office	12	PASSED
1627709	Intey Laminator	Exposed Cables - Recommend Repair or Replace											RG	Nickys Office	12	FAILED
1627710	Canon Battery Charger	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Nickys Office	12	PASSED
1627711	2 Pin Lead	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Nickys Office	12	PASSED
1627712	Safescan 1250GBP	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Nickys Office	12	PASSED
1627713	Philips Monitor PSU	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Nickys Office	12	PASSED
1627714	IEC Lead	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.03	OK	230	RG	Nickys Office	12	PASSED
1627715	4 Gang Extension Lead	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.07	OK	230	RG	Nickys Office	12	PASSED
1627716	Epson ET-16500 Printer	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Nickys Office	12	PASSED
1627717	IEC Lead	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.04	OK	230	RG	Nickys Office	12	PASSED
1627718	HP Desktop PC	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.05	OK	230	RG	Nickys Office	12	PASSED
1627719	IEC Lead	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.03	OK	230	RG	Nickys Office	12	PASSED
1627720	IEC Lead	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.1	OK	230	RG	Reception Office	12	PASSED
1627721	IEC Lead	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.04	OK	230	RG	Reception Office	12	PASSED
1627722	Cisco Network Switch PSU	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Office	12	PASSED
1627723	IEC Lead	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.05	OK	230	RG	Reception Office	12	PASSED
1627724	Netgear Prosafe Network Switch PSU	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Office	12	PASSED
1627725	Draytek Vigor 130 Network Switch	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Office	12	PASSED
1627726	Unknown PSU	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Office	12	PASSED

Asset ID	Description of Item	Visual Only	Class	Supply Test	Connector / Plug Check	Case / Housing Check	Fuse Check	Visual Result	Insulation Result MΩ	Earth Bond Ω	Polarity	Voltage	Test Engineer	Location	Retest Due (Months)	Overall Pass / Fail
1627727	2 Pin Lead	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Office	12	PASSED
1627728	Unknown Power Lead	Visual Inspection Only											RG	Reception Office	12	PASSED
1627729	6 Gang Extension Lead	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.05	OK	230	RG	Reception Office	12	PASSED
1627730	Qnap NAS PSU	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Office	12	PASSED
1627731	IEC Lead	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.05	OK	230	RG	Reception Office	12	PASSED
1627732	Tooway Viasat PSU	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Office	12	PASSED
1627733	IEC Lead	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.07	OK	230	RG	Reception Office	12	PASSED
1627734	Panasonic Phone PSU	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Office	12	PASSED
1627735	Dell Monitor	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Office	12	PASSED
1627736	IEC Lead	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.06	OK	230	RG	Reception Office	12	PASSED
1627737	HP Tower PC	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.05	OK	230	RG	Reception Office	12	PASSED
1627738	IEC Lead	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.04	OK	230	RG	Reception Office	12	PASSED
1627739	PowerDsine Network Adaptor	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Office	12	PASSED
1627740	IEC Lead	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.07	OK	230	RG	Reception Office	12	PASSED
1627741	4 Gang Extension Leaf	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.05	OK	230	RG	Reception Office	12	PASSED
1627742	Generic 4 Port USB Hub PSU	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Office	12	PASSED
1627743	CS PSU	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Office	12	PASSED
1627744	HP Envy 4524 Printer/Scanner	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Office	12	PASSED
1627745	2 Pin Lead	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception Office	12	PASSED
1627746	World Pay Card Reader	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception	12	PASSED
1627747	2 Pin Lead	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception	12	PASSED
1627748	Panasonic Phone PSU	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception	12	PASSED
1627749	Olivetti ECR7100 Till	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Reception	12	PASSED
1627750	Silver Lamp	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Bungalow Bedroom	12	PASSED
1627751	Silver Lamp	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Bungalow Bedroom	12	PASSED
1627752	Amazon USB Charger	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Bungalow Bedroom	12	PASSED
1627753	Samsung PSU	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Bungalow Bedroom	12	PASSED
1627754	John Frieda Hair Dryer	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Bungalow Bedroom	12	PASSED
1627755	Bush Radio Alarm Clock	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Bungalow Bedroom	12	PASSED
1627756	Brass Effect Bedside Lamp	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.09	OK	230	RG	Bungalow Bedroom	12	PASSED
1627757	Brass Effect Bedside Lamp	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.09	OK	230	RG	Bungalow Bedroom	12	PASSED
1627758	Dyson DC-33 Vacuum Cleaner	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Bungalow Utility	12	PASSED
1627759	Hotpoint Tumble Dryer	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.01	OK	230	RG	Bungalow Utility	12	PASSED
1627760	Bosch VarioPerfect Washing Machine	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.05	OK	230	RG	Bungalow Utility	12	PASSED
1627761	Samsung USB Charger	0	2	PASS	PASS	PASS	PASS	PASS	>199	N/A	OK	230	RG	Bungalow Kitchen	12	PASSED
1627762	Bosch Dishwasher	0	1	PASS	PASS	PASS	PASS	PASS	>199	0.08	OK	230	RG	Bungalow Kitchen	12	PASSED

PAT Testing Certificate for

Sample - OD12345

February 2020

This certificate confirms that on date above, portable appliance testing (PAT) was carried out at the above named site as per the guidance and regulations set out in The IET Code of Practice for The Inspection and Testing of Electrical Equipment. At the time of testing, all equipment that attained a pass result, did so by meeting the standards set out in this document.



Signed: Mr Mike Holland Porter: NICEIC Qualifying Manager

A handwritten signature in black ink, written over a horizontal dotted line.

February 2020

Signed: Mr James Canter: Reaction Group Managing Director

A handwritten signature in black ink, written over a horizontal dotted line.

February 2020



2013/665

2013/665